



**ELEVATION**

General Notes:

1. All dimensions are in inches unless otherwise specified.
2. Steps shall be provided at 16" O.C. and shall be copolymer polypropylene plastic with a continuous 1/2-inch steel reinforcement, not to be positioned over inverts
3. Adjustment: Three adjustment rings totaling 8" in height may be used. No more than two (2) of those rings may be precast concrete. The top ring in paved areas with crown adjustments shall be rubber.
4. When adjusting rings are required on structures, provide ADCCO WT-64 butyl sealant (or approved equal) between the adjusting rings and the structure.
5. Butyl rubber joint sealant by EZ-Stik (or approved equal) shall be applied on barrel section joints.
6. Structure shall be placed on a minimum 6" CA-6 granular bed.

<b>Sanitary Manhole</b>
SAN-1 102407