



General Notes:

1. All dimensions are in inches unless otherwise specified.
2. Depths: 12' or less should comply with SDR 26 PVC sewer pipe per A.S.T.M. D-3034.
3. Installations between 12' and 20' deep shall be SDR 21.
4. Installations over 20' deep shall be class 52 ductile iron.
5. New services to be PVC only.
6. Bedding should be CA-7 and backfill should be CA-6.
7. Service inverts shall be at or above the crown of the mainline sewer.

Sanitary Service

SAN-2 102407