



Romac 202N for existing CI and AC mains (direct tap for DI)
 Note: Full stainless steel, tapped sleeve may be required depending on condition of main

Corporation stop A.Y. McDonald
 4701BT or 4701BP (Ball Type)
 Swivel nut 4750 ST required for 1 1/4" and 2" services

Curb stop A.Y. McDonald
 6104BT (Ball Type,
 Minneapolis Pattern)

1" Type K copper tubing
 or Village approved size

Support brick

- General Notes:
1. No couplings permitted between corporation and curb stop.
 2. No couplings permitted between curb stop and building.
 3. B-boxes should be located in grassy, non-paved areas.

Water Service
W-4 012908
Revised 070909